



### TRACTION NETWORK MONITORING AND PROTECTION SYSTEM SMTN-3

CITY ELECTRIC TRANSPORT

### TRACTION NETWORK MONITORING AND PROTECTION SYSTEM

With increased traffic stream and reduction of rolling stock movement interval arises an ever-greater need for intelligent relay protection devices provided for contact networks protection against overloads and short circuit currents. For these purposes, PLUTON experts developed **innovative traction network monitoring and protection system SMTN-3**, the third generation of protection devices based on leading-edge technologies.

Traction network monitoring and protection system, series SMTN-3 is provided for:

- traction network protection against short circuit current and harmful overloads;
- traction network parameters monitoring in real-time;
- data acquisition for the following analysis of emergency processes;
- providing operating personnel with data in the shortest time possible for the following analysis.

# COMPLIANCE WITH INTERNATIONAL STANDARDS

Traction network monitoring and protection system SMTN-3 produced by PLUTON was successfully type-tested for compliance with the standards of International Electrotechnical Commission (IEC) in Aucoteam GMBH Test Center (Berlin, Germany).

Traction network monitoring and protection system corresponds to international standards:

- IEC60068-2 ("Environmental tests"),
- IEC60255-21 ("Electrical relays Part 21: Vibration, shock, seismic resistance"),
- IEC 60255-26 ("Measuring relays and protection systems part 26: Requirements to electro-magnetic compatibility").

### **APPLICATION AREA**

SMTN-3 is applied in traction substations switchgears:

- in city electric transport,
- metro,
- railways,
- industrial enterprises,
- mining industry.

CULLITY TEST CERTIFICATE Test report - no. 12003 / 16  Cut  Excursor  Excursor  Factor and the port - no. 12003 / 16  Cut  Excursor  Factor and the port - no. 12003 / 16  Cut  Factor and the port	nd conteilve environmental atrees	
Test report - no. 12003 / 19	QUALITY TEST CEI	RTIFICATE
Conservation of the servation of the ser	Test report - no. 12	2003 / 16
An and a set of a set	Swit .	
training     Training       training     T		AUCOILAM
Brance Barrier Ba	pupment u	
Array and a set of the set o	Testing laboratory for clima	dir, mechanical
Control C	and concerne environment	a stess
Type:         The report - no. 12002 / 16           market         The report - no. 12002 / 16	Course Q	UALITY TEST CERTIFICATE
Arose	Nontro and	Test report - no. 12002 / 16
The property of the property o	anyone anyone to physical and the physical strategy and the physical s	
The pages The page The pag	Cient	Paden Jaint Black Company
Tel right in the second	Cont	S Novoetroyek st.
The peer in the pe	and burdland	BBC76 Ukraine
An analysis of the second and analysis of the second analysis	Equipment under test	Traction Network Monitoring and Protection System - 58
Consider a manual model of the second model of	an party	3e processing module (PM) 3e maisuring module (MM)
Purpue         Find of the development instruction and of the situation           The number         The purpue           Provide         The number           Provide         The number           Provide         The number           Provide         The number           Provide 1.         The number of the	secular le	including connection cables
That Autres         memory and products, QC 20000 M 2 and AUC 2000 M 2 AND A	Purpose	Test of the dynamic-mechanical and of the climatic stabil
Tare party in         Order	Istal number	demands of the client, IEC 60068-2-ft and IEC 60255-21-
Tari tuda         Dynamic	Text program	Cold - Next A acc. for JEC 60068-3
Rev increased adapt - even the sum of the case of of the cas	ant results	Dry beat - leaf B and, for AEC 60008-2
Provide A Norma Control         Entrol Control In Control Norma Control         Entrol Control In Control Norma Control Norma Control         Entrol Control In Control Norma Control Norma Control In Control Norma Control Norma Control Norma Contr		Slow temperature change - test Nb acc. to /EC 60086.2
Device A	P	Damp heat, already state - test Cab acc. fo JEC 60068-2
Name of the set of th	an ing R.	Dump heat, cycline - level Do and. In ACC 60008-2
Andre 2 A	wad of the l	Shard - had for any to 20 4008.2
The panel State of the second state of the sec	lertin, 28 Ap	Free felt - lead Ex and, for JEC 60089.2
Territoria de la construcción de	Taxa sector	No. and No. of Long West
Total number of pages 22 (not 24 pages films) Total number of pages 22 (not 24 pages films) The tasks areas carted on controls of the specific term of the same tasks of the s	Execution / mail in	are called 2 to 9
Test much. The tests are carried out according to the specific the standards and the document of the standard	Total number of pages	22 (mol. 3 appendices)
P. L. Your Market and to the classifier of the class. P. L. Youther contraction will be done by the class.	Test reads	The tests were carried out according to the energie allow
P. L. Further evolution will be done by the class.		the standards and to the demands of the client.
Tide- Anno X. 42	DO	Further evaluation will be done by the client,
	T. de-	ALT AL
Head of the leading laboratory (* ( )*) Recent Singlet, M. 1 Test engineer	Head of the testing laborat	ory (*()*) Recent Singlet M. Sc.
Berlin, 14 June 2016	Berlin, 14 June 2016	AB TOTAL P
	1.1011.0420-01000	- Course of the



TRACTION NETWORK MONITORING AND PROTECTION SYSTEM SMTN-3

PLUTC7

### SYSTEM CAPABILITIES

Traction networks protection is provided by monitoring of traction network voltage and current dynamics change. In case of protective functions preset parameters exceed the system issues a command to open high speed circuit breaker.

SMTN-3 provides the following operation capabilities:

- **measurement** of traction network voltage and current value and shape in different modes, including short-circuit in line;
- **protection** of traction network against short-circuit currents, including remote short circuits low currents and overloads;
- oscillography and long-term memory record of voltage and current value and shape under short circuits (one of emergency process protections detection in traction network);
- waveforms storage and display, as well as data for further analysis transfer to upper level system (or PC);
- **software-based internal configuration setting** (protections input, protective characteristics selection, number of protection stages, etc.);
- local and remote input, storage and display of protection settings;
- **storage of two setting sets** and switching of setting sets by external signal;
- **information** on the number and time of protections operation storage and **output**;
- **analysis** of current distribution between incoming panels.



▲ SMTN-3 system modules

### BENEFITS

- traction network protection against short circuit current and harmful overloads;
- remote data access using Ethernet and Web interface;
- high reliability and computing power;
- high speed and high value measuring accuracy;
- international standards compliance.

### SYSTEM MODULS

SMTN-3 is designed as a set of separate modules, fixed on DIN-rail and connected with each other:

- measuring module with voltage divider is located in high voltage area (busbar compartment);
- **processing module** is located in low voltage area (control compartment).

Measuring and processing modules are interconnected with optic cable that provides transmission of information between modules, as well as galvanic isolation between high voltage measuring circuits and secondary circuits.





▲ Functional diagram



▲ SMTN-3 system modules in assembly with DC switchgear



### SYSTEM COMPONENTS FUNCTIONS



▲ Processing module

#### Processing module

Processing module processes all the data received from measuring module and other additional modules, as well as digital inputs. Processing module consists of several computer systems, interconnected with data busbars.

#### Main functions:

- primary processing and storage of current data from measuring module;
- current and voltage values normalization;
- validity diagnostics and control of data received from measuring module;
- protection functions (analysis of data from measuring module according to protection algorithms);
- generation of switching devices emergency tripping signals in accordance with protection functions;
- registration and storage of traction network emergency processes data;
- system events logging;
- system settings storage;
- system self-test;
- communication with traction substation automated control system upper-level system;
- access to changing and configuration of system parameters using "Human Machine" interface (HMI).

#### Measuring module

Measuring module is directly connected to voltage and current measurement primary sensors. Current sensor is a resistive element of power circuit (shunt). Voltage sensor is a resistive voltage divider located inside measuring module. It is provided for the measured voltage reduction to the level suitable for further processing in the electronic modules.

#### Main functions:

- matching with the primary sensors (shunts, voltage dividers);
- galvanic isolation of low voltage circuits from traction network high potential using static power supply unit;
- processing of analog input electrical quantities to match them with processing module interfaces;
- pre-filtering of input signal based on analog and digital filters;
- transfer of input electrical values analog processed data in processing module using optic cable.



▲ Measuring module

### **PROTECTION FUNCTIONS**

SMTN-3 provides smooth and reliable operation of the system, as well as filtering against false tripping.

It performs the following **protection functions:** 

- instantaneous overcurrent;
- overcurrent protection;
- current rate of rise protection;
- current increment directional protection;
- overvoltage protection;
- undervoltage protection;
- thermal protection;
- breaker failure.

### ADDITIONAL FUNCTIONS

Optionally, the system is equipped with the following systems (modules) that extend functional range of the system as a whole:

- line tester (short circuits tester);
- cable insulation control system.

Cable insulation control system continuously monitors cable insulation resistance and in case of insulation degradation gives a warning signal to open high-speed circuit breaker.

Cable insulation control system is provided for internal and external cable insulation resistance values measurement in traction networks up to 1000 V DC.

Data transfer between cable insulation control system and SMTN-3 central unit is going via optical fiber. Moreover, optical fiber provides electrical isolation between systems modules and ensures safe usage of device.



▲ Line tester (short circuits tester)

Line tester (short circuits tester) allows to determine line impedance before high-speed circuit breaker closing. In case if line impedance is lower then the setting parameter, the system issues a prohibition to close high-speed circuit breaker.



▲ Cable insulation control system



### EVENTS AND PARAMETERS LOGGING

SMTN-3 generates and stores the following records:

- events log;
- failures log;
- emergency oscillograph records.

The records are stored on nonvolatile solid data storage medium, that guarantees high reliability and data storage in case of devices power supply interruption.

SMTN-3 system provides generation and storage of emergency oscillograph records. Emergency oscillograph record generation is performed when one of protective functions operates.

Two records of emergency oscillograph are generated and saved when one of the protection functions operates:

- "Fast track";
- "Slow track".

Emergency oscillograph records include:

- current and voltage oscillogram generated directly from the measured values (sampling period 50 µs for "Fast track" and 100 ms for "Slow track"); state diagram of digital inputs and outputs for the entire duration of voltage and current oscillogram recording;
- track generation astronomical time;
- kind of tripped protection;
- tripping protections settings.

The length of "Fast track" and "Slow track" oscillograms is fixed and contains 2048 current and voltage values. "Fast track" and "Slow track" oscillograms contain successive current and voltage values up to one of protection functions tripping (hereinafter "Prehistory") and after one of protection functions tripping (hereinafter "Post-history").

Number of current and voltage values in "Prehistory" for each track is an individually set parameter and can be changed with the help of settings.

SMTN-3 stores up to 200 records of emergency processes. When the limit is exceeded, a new record will be saved instead of the oldest one.

SMTN-3 system also logs maximum values of current and voltage. When newly measured current or voltage values exceed the previously logged ones, new values are recorded instead of old ones. Comparison is made independently for current and voltage channels.

Recorded maximum values can be reset, provided that new maximum values logging cycle begins anew.

Time of each record is:

- "Fast track" 100 ms;
- "Slow track" 100 s.



▲ HMI interface on panel PC screen



Emergency records can be viewed using Web interface, read by upper level system via Ethernet or saved on external USBdisk for later analysis using a PC.



#### ▲ Access to system data



▲ Parameters setting in Web interface

TRACTION NETWORK MONITORING AND PROTECTION SYSTEM SMTN-3



### PARAMETERS SETTING

SMTN-3 system provides the following methods of parameters setting, both of the system itself and protection functions parameters:

- local "Human Machine" interface based on LCD touch screen;
- remote "Human Machine" interface based on Web technologies;
- remote access to device using ModbusTCP/IP protocol, for upper level systems and power management systems, etc.

Remote "Human Machine" interface based on Web technology is an integrated Web server in each SMTN-3 processing module.

It does not require any additional software installation on computer. This interface is used to configure, display and analysis of data acquired by SMTN-3 system.

Communication with SMTN-3 Web server can be fulfilled via Ethernet cable or by wireless connection via PC, tablet or smartphone. Only Web browser installed on the device is needed to work with SMTN-3 Web server.

"Human Machine" interface is in English and Russian languages. The interface can also be implemented in other languages.

PLUTCN



▲ Remote viewing of emergency records





🕅 Language	^							
Status			Protection BF			Thermal protection (I(t))		
Event Log		BE	Current setting	50	A	Thermal protection (I(t))		
🖮 Tracks			Time exposure	200	ms	Switching mode	manual	\$
Measuring module		Time exposure 200 ms		Active I(t) group	Group I(t)-1	\$		
✤ Settings	^							
Inputs / Outputs		Line Test Device (LTD)		Group	s settings			
Network								
? About		LTD Setting 300 V		Switching mode	manual	\$		
Turn on keyboard				Active group	Group 1	¢		
		Vo	tage Control Relay (V	CR)				
		VCR	Setting	100	v			

▲ Parameters setting screen in Web interface

## MAIN TECHNICAL DETAILS OF TRACTION NETWORK MONITORING AND PROTECTION SYSTEM SMTN-3

Name of parameter		Value		
Main parameters				
Number of current measuring channels	pc.	1		
Number of voltage measuring channels	pc.	1		
Type of current sensor	-	Shunt		
Power circuit voltage measuring range	V	-2000+2000* -8000+8000*		
Input voltage range for power circuit current measuring channel (DC generated voltage on shunt)	V	-0.5+0.5		
Current measuring range where: Ish – shunt rated current; Ush – voltage drop on shunt under rated current.	А	$I_{max} = \pm \frac{0.4 \cdot I_{sh}}{U_{sh}}$		
Measured values sampling period	μs	50		
Current measuring accuracy, max, of Ish	%	0.5		
Voltage measuring accuracy, max, of measuring range	%	0.5		
Insulation strength between measuring module power circuit and power supply circuit, minimum	kV	10 (30)*		
Measured values				
	-	Current (current channel) Voltage (voltage channel) Power (calculated) Energy (calculated) Test current (Line tester channel)		
External signals				
Number of high speed digital outputs	pc.	5		
Digital outputs designation	-	Signals issuing is set individually for each output under one or several protection functions tripping		
Number of digital inputs	pc.	5		
Digital inputs designation	-	Set individually for each input: HSCB condition control, external opening signal, timesync.		
Power supply				
Rated operating voltage	V	==5; 12; 24 ; 48, 110; 220 ≂ 110; 220		
SMTN-3 system max consumed power, max	W	15		
Permissible voltage long-term tolerances	%	-15+10		
Communication interfaces				
Data transfer interface	-	Ethernet		
Data transfer protocols	-	Web technologies Modbus TCP/IP		
Reliability				
Mean Time Between Failures (MIL-HDBK-217F)	hours	100 000		
Total average lifetime (under condition of the required technical maintenance activities provision)	years	25		



Name of parameter		Value
Design		
Protection degree of modules in acc. with DIN VDE 0470 and EN 60529 or IEC 529		IP3X
Cooling		natural, air
Type of modules mounting		DIN-rail (TH 35, EN 50022)
Protection functions		
Code ANSI	50 76 59 27 49 BF	Instantaneous overcurrent Overcurrent protection Current rate of rise protection Current increment directional protection Overvoltage protection Undervoltage protection Thermal protection Breaker failure
Period of data processing by protective functions algorithms	μs	50
Number of settings groups		2
Measuring and logging functions		
Measured values		Current Voltage Power Energy HSCB tripping counter Test Current (Line tester Channel)
Number of recorded oscillograms under emergency event** occurrence	pc.	2 "Fast track" "Slow track"
Emergency oscilligraph records coverage width		Current curve; Voltage curve; Digital inputs and outputs state diagram; Astronomical time; Type of tripped protection.
Emergency oscilligraph records coverage depth	points	2048 (for each measured value)
Signals sampling frequency in "Fast track" record	kHz	20
Signals sampling period in "Slow track" record	Hz	10
"Fast track" record time coverage depth	ms	100
"Slow track" record time coverage depth	S	100
Prehistory *** record time coverage depth in "Fast track" record	points	Set 0 - 2048
Prehistory *** record time coverage depth in "Slow track" record	points	Set 0 - 2048
Number of emergency oscillograph stored records		200
Local human interaction interfaces		
		LCD touch-screen or LED indication and control element
Operating conditions		
Ambient temperature range	°C	+1+60
Relative air humidity, under temperature (Upper value)	%	60, 20 °C (80, 25 °C)

\* - depending on measuring module design, for application in city electric transport with traction network voltage up to 1000 V or for application in railway transport with traction network voltage up to 4000 V

\*\*- one of protections tripping is considered to be emergency event

\*\*\* - prehistory is a diagram of measured values up to emergency event occurrence



#### TRACTION NETWORK MONITORING AND PROTECTION SYSTEM TYPE TESTS

Name of parameter	Normative	Note
Electric tests	IEC 255-5	-
EMC compliance tests		
Radio interference voltage on power supply terminals	IEC 60255-26 CIS PR 22, class A	Frequency range: (0.15 – 30) MHz
Radio interference field intensity	IEC 60255-26 CIS PR 22, class A	Frequency range: (30 – 6000) MHz Measuring distance: 3 m
Radiated electromagnetic field immunity	IEC 60255-26 IEC 61000-4-3	Frequency range: (80 – 1000) MHz, Field intencity: 10 V/m
Conducted interference immunity, inducted by radio-frequency electromagnetic field	IEC 60255-26 IEC 61000-4-6	Frequency range: (0.15 – 80) MHz Interference voltage: 10 V
Nanosecond pulses immunity	IEC 60255-26	Test pulses amplitude: - signal and feed lines – ± 4 kV - communication lines – ± 2 kV Pulse repetition frequency – 5 kHz Test pulse: 5/50 ns
Electrostatic discharge tolerance (EDS)	IEC 60255-26 IEC 61000-4-2	Air discharge  - ± 8 kV Contact discharge  - ± 6 kV
Microsecond pulse interference immunity	IEC 60255-26 IEC 61000-4-5	Test pulse: 1,2/50 µs Test pulses amplitude: - signal and feed lines: "two-wire" – ± 2 kV "earth-return" – ± 4 kV - communication lines: "earth-return" – ± 4 kV
Power frequency magnetic field immunity	IEC 60255-26 IEC 61000-4-18	Magnetic field intensity: 100 A/m
Power failures and interruption resistance	IEC 60255-26 IEC 61000-4-11	Power failure: U int. min - 30 % - 500 ms U int. min - 60 % - 200 ms Power interruption: - 20 ms
Decaying oscillatory waves resistance	IEC 60255-26 IEC 61000-4-18	Frequency: 1 MHz Signal and feed lines: - "two-wire" - 1 kV - "earth-return" - 2.5 kV Communication lines: - "earth-return" - 1 kV

TRACTION NETWORK MONITORING AND PROTECTION SYSTEM SMTN-3



Name of parameter	Normative	Note
Mechanic tests		
Sinusoidal vibration influence immunity	IEC 60068-2-6 IEC 60255-21-1	Frequency: 2-200 Hz; Acceleration amplitude 20 m/s² (2 g) Scanning rate: 1 octave/min Duration: 20/axe In 3 orthogonal axes
Single-impacts immunity	IEC 60068-2-27 class 2	Acceleration amplitude - 100 m/s² (10g); Pulse duration –11 ms, 3 impacts per each of 6 directions
Long-term impacts immunity	IEC 60068-2-27 class1	Acceleration amplitude - 100 m/s²(10g); Pulse duration – 16 ms, 1000 impacts per each of 6 directions
Transportation and storage	IEC 60255-21-2 IEC 60068-2-27	Vertically: - 750 m/s <sup>2</sup> , 6 ms, 200 picks - 150 m/s <sup>2</sup> , 11 ms, 2000 picks - 100 m/s <sup>2</sup> , 11 ms, 8800 picks Horizontally: - 120 m/s <sup>2</sup> , 11 ms, 400 picks
Free fall resistance	IEC 60068-2-31	Height 1 m From 6 sides
Climatic tests		
Ad test: Cold, in operation	IEC 60068-2-1	-10 °C Holding: 72 h.
Ab test: Cold, off-load	IEC 60068-2-1	-40 °C Holding: 72 h.
Bd test: Sensible heat, in operation	IEC 60068-2-2	+60 °C Holding: 72 h.
Bb test: Sensible heat, off-load	IEC 60068-2-2	+60 °C Holding: 72 h.
Nb test: Temperature drift	IEC 60068-2-14	Minimum temperature  -10 °C Maximum temperature  +55 °C Holding: 3 h. 2 cycles
Cab test: Damp heat. Constant mode	IEC 60068-2-78	Temperature  +55 °C Humidity  93 % Holding: 96 h.
Db test: Damp heat. Cyclic mode	IEC 60068-2-30	+25 °C/ 95 % -> +55 °C/ 93 % Holding: 12 h. 2 cycles +55 °C/ 93 % -> +25 °C/ 95 % Holding: 12 h. 2 cycles

PLUTON Polska 16 Mazura str. 02-830 Warsaw, Poland

Tel./Fax: +48 22 111 50 31

E-mail: office@pluton-polska.pl www.pluton-polska.pl LLC PLUTON IC 4-B Lukasha M. st., office 1 Lviv, 79026 Ukraine

Tel./Fax: +380 (61) 239-79-00 +380 (61) 239-79-01

E-mail: info@pluton.ua www.pluton.ua







